


Irrigation Requirements for Backflow

All lawn irrigation systems shall be protected from potential cross connections with a Pressure Type Vacuum Breaker. The PVB shall be installed a minimum of twelve (12) inches above all in ground heads. The PVB is not required to be installed above shrub risers or other above ground heads where the heads is located a minimum of twelve (12) inches above grade. In order to protect the PVB against the possibility of freezing each riser shall be equipped with a means to drain it. In addition to draining, each riser shall also be equipped with additional means to prevent freezing such as heat tape, hot box or other approved freeze protection devices. To assist with freeze protection, repairs, and general maintenance, each irrigation system shall be equipped with a manual shut off valve. The shut off valve shall be located at or adjacent to the connection to the water supply.

Prior to approval of an irrigation system a test of the backflow device must be performed. Once the test has been approved leave the report in the Town of Argyle permit packet and the inspector will pick it up.



(940) 464-7273

506 N. Hwy 377
Argyle, Texas 76226

Residential Building Permit Application

Building Permit Number: _____ Zoning: _____ Lot Platted: Y / N _____
 Project Address: _____ Project Value: _____
 Lot: _____ Block: _____ Subdivision: _____
 Project Description: NEW REMODEL/ADDITION OTHER (SPECIFY): _____
 PLUMBING MECHANICAL ELECTRICAL
 FENCE ACCESSORY BUILDING LAWN IRRIGATION SWIMMING POOL
 Description of Work: _____
 Living Area (sf): _____ Garage (sf): _____ Porch (sf): _____ Total (sf): _____ Number of stories: _____

Owner Information: _____ Email: _____
 Name: _____ Contact Person: _____
 Address: _____
 Phone Number: _____ Fax: _____ Mobile: _____

General Contractor	Contact Person	Phone Number	TRCC License Number
Mechanical Contractor	Contact Person	Phone Number	Contractor License Number
Electrical Contractor	Contact Person	Phone Number	Contractor License Number
Plumber/Irrigator	Contact Person	Phone Number	Contractor License Number

A permit becomes null and void if work or construction authorized is not commenced within 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work is commenced. Separate permits are required for electrical, plumbing, and heating and/or air conditioning. All permits require final inspection.

I hereby certify that I have read and examined this application and know the same to be true and correct. All provisions of laws and ordinances governing this type of work will be complied with whether specified or not. The granting of a permit does not presume to give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction.

Signature of Applicant: _____ Date: _____


OFFICE USE ONLY:

Approved by:		Date Approved:	
--------------	--	----------------	--

Grading, Drainage and Excavation Permit Fee: \$ _____
 Building Permit Fee: \$ _____ Sewer Tap Fee: \$ _____
 Plan Review Fee: \$ _____ Wastewater Impact Fee: \$ _____
 Electrical Permit Fee: \$ _____ Drive/Culvert Permit Fee: \$ _____
 Mechanical Permit Fee: \$ _____ Septic Permit Fee: \$ _____
 Plumbing Permit Fee: \$ _____ Roadway Impact Fee: \$ _____

Total Permit Fees: \$ _____
 Issued Date: _____
 Issued By: _____
 BV Project #: _____

Construction Hours: Monday - Friday, 7:00 a.m. to 6:00 p.m. and Saturday 7:00 a.m. to 5:00 p.m.
No Work allowed on Sundays. The Town of Argyle has a zero tolerance policy on construction hours.
First time violators will be cited.



Bureau Veritas Contact Info.

Permit Submittal:

The permit documents and fees will be submitted to the Town. Submittal documents should be complete to expedite plan review and permit issuance. Please contact the city for a complete list of permit submittal requirements.

Plan Review:

Bureau Veritas will be conducting residential and commercial plan reviews. The applicant will be contacted by Bureau Veritas if revisions are needed. You may contact Bureau Veritas' Plan Review Department for the status of your permit at (817) 335-8111, (972) 980-8401, or toll free (877) 837-8775.

Inspection Requests:

Please contact Bureau Veritas to request inspection (s). Any of our permit technicians can assist you. Inspections requested by 5:00 pm Monday-Friday will be performed the next business day. Inspection requests can also be faxed to the Bureau Veritas office.

Inspection Line: (817) 335-8111 or (972) 980-8401
Inspection FAX line: (817) 335-8110 or (972) 980-8400
Toll Free Number: (877) 837-8775
Toll Free FAX line: (877) 837-8859

Field Inspections:

Inspectors assigned to your area can be contacted via cell phone. Please call the Bureau Veritas for your inspector's name and number.

We look forward to working with you to ensure that the community is provided with a safe and durably built environment.